

Dry Water Year Type			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	70 cfs	124 cfs	124 cfs
December	70 cfs	142 cfs	142 cfs
January	70 cfs	187 cfs	187 cfs
February	70 cfs	195 cfs	195 cfs
March	70 cfs	172 cfs	172 cfs

Normal Water Year Type			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	95 cfs	124 cfs	124 cfs
December	95 cfs	142 cfs	142 cfs
January	95 cfs	187 cfs	187 cfs
February	95 cfs	195 cfs	195 cfs
March	80 cfs	172 cfs	172 cfs

*Federal Energy Regulatory Commission has issued a new license to the Pacific Gas and Electric Company for the DeSabla-Centerville Hydroelectric Project, which asserts minimum instream flow requirement at USGS gage 11390000 as summarized in the above table.

Web Link to Water Quality Certification:

[Water Quality Certification for the DeSabla-Centerville Hydroelectric Project](#)